

2018 Annual Drinking Water Quality Report

(Consumer Confidence Report)

CITY OF DECATUR
Phone No: **940-393-0200**
Public Water System (PWS) 2490005

Annual Water Quality Report for the period of January 1 to December 31, 2018

This report is intended to provide you with important information about your drinking water and the efforts made by the City of Decatur to provide safe drinking water.

The source of drinking water used by the CITY OF DECATUR is Surface Water. This report is available on the City website at: <http://www.decatortx.org/>

For more information regarding this report contact: Doyle Green at 940-393-0260

Information on Sources of Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at: (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Public Participation Opportunities

Date: JULY 8th, 2019
Time: 6:00 pm
Location: DECATUR CITY HALL
201 East Walnut Street
Phone No: 940-393-0200

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Health Information for Special Populations

Required Language for ALL Community Public Water Systems

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español, favor de llamar al tel. (940) 393 - 0200 - para hablar con una persona bilingüe en español.

Information About Source Water Assessments

The Texas Commission on Environmental Quality completed an assessment of the City of Decatur source water and results indicate that some of the sources are susceptible to certain contaminants. The sampling requirements for the City water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Doyle Green at 940-393-0260.

Source Water Name <u>LAKE BRIDGEPORT</u>	Type of Water <u>SW</u>	Report Status <u>Active</u>	Location <u>Lake Bridgeport</u>
---	----------------------------	--------------------------------	------------------------------------

Definitions and Abbreviations: The following tables contain scientific terms and measures, some of which may require explanation.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E.coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level or MRDL: The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

- MFL:** million fibers per liter (a measure of asbestos)
- mrem:** millirems per year (a measure of radiation absorbed by the body)
- na:** not applicable
- NTU:** nephelometric turbidity units (a measure of turbidity)
- pCi/L:** picocuries per liter (a measure of radioactivity)
- ppb:** micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
- ppm:** milligrams per liter or parts per million – or one ounce in 7,350 gallons of water
- ppq:** parts per quadrillion, or picograms per liter (pg/L)
- ppt:** parts per trillion or nanograms per liter (ng/L)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E.Coli Maximum Contaminant Level	Total No. of Positive E.Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# of Sites Over (AL)	Units	Violation	Likely Source of Contamination
Copper	8/16/2016	1.3	1.3	0.1	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	8/16/2016	0.0	15	1.4	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2018 Water Quality Test Results

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2018	32	20.6 – 38.9	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
<small>*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.</small>								
Total Trihalomethanes (TTHM)	2018	71	46.4 – 70.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
<small>*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.</small>								

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2018	0.049	0.049 - 0.049	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2018	81.8	81.8 – 81.8	200	200	ppb	N	Discharge from plastic and fertilizer factories; discharge from steel/metal factories.
Fluoride	2018	0.1	0.104–0.104	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	2018	0.218	0.218 – 0.218	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	3/10/2016	4.7	4.7 – 4.7	0	50	pCi/L*	N	Decay of natural and man-made deposits.
<small>*EPA considers 50 pCi/L to be the level of concern for beta particles.</small>								
Combined Radium 226/228	3/10/2016	1.5	1.5 – 1.5	0	5	pCi/L	N	Erosion of natural deposits.

Maximum Residual Disinfectant Level

Systems must complete and submit disinfection data on the Surface Water Monthly Operations Report (SWMOR). On the CCR report, the system must provide disinfectant type, minimum and average levels.

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation	Source of Chemical
Chloramines	2018	3.8	3.1	4.8	4.0	<4.0	ppm	N	Disinfectant source used to control microbes.

Turbidity

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest Single Measurement	0.08 NTU	1 NTU	N	Soil Runoff.
Lowest Monthly % Meeting Limit	100%	0.3 NTU	N	Soil Runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.